



CERTIFICATE FI 26825 M1

Our Ref. 261140-1, 270387-2

Product Heating cable
Types FHCS, FHCT
Trade mark THERMOPADS
**Certificate Holder/
 Manufacturer** Thermopads Pvt. Ltd.
 Plot No: 28, Nagarjuna Hills, Punjagutta
 HYDERABAD, 500 082
 INDIA
Technical information Max. 20 W/m, 300/500 V
 Rated temperature 70°C, Class M2
 With cold lead, splice and end seal
Other information See the Appendix to this Certificate
**The product is certified
 according to the
 following standard(s)** IEC 60800:2009 (Ed 3)

Validity This certificate is valid until 17 May 2016 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Directive information The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.


Date of issue

SGS Fimko Ltd

Signature

Sixten Lökfors
 Project Manager

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 26825 M1

Manufacturing site

Thermopads Pvt. Ltd.
F - 10/B, Phase - I, IDA Jeedimetla
HYDERABAD 500 055
INDIA

Additional information

FHCS Floor heating cable, Single core
FHCT Floor heating cable, Twin core

Construction:

- heating conductor, solid/stranded
- insulation, fluoropolymer or XLPE
- metal shielding
- outer sheath, polyolefin/PVC

Joints and terminations IPX7

For fixed supply or with plug

This certificate replaces previous FI Certificate no. 26825,
dated 17 May 2011, due to updated construction.