



Product Service

# CERTIFICATE

No. B 111044 0003 Rev. 00

**Holder of Certificate:** **Yueqing Zeyi Electric Appliance Co., Ltd**  
Sifang Village, Beibaixiang Town, Yueqing City  
325600 Wenzhou City, Zhejiang Province  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** **Low voltage switchgear combination  
Electromechanical contactors for  
household and similar purposes**

**Model(s):** **HC-263, HC-463**

**Parameters:**

Rated impulse withstand voltage (Uimp):	4,0kV
Rated insulation voltage (Ui):	440V
Conventional free air thermal current (Ith):	63A
Rated operational voltage (Ue):	AC230V (HC-263), AC400V (HC-463)
Rated frequency:	50/60Hz
Rated operational current (Ie):	AC-7a: 40A, 63A; AC-7b: 32A
Utilization category:	AC-7a, AC-7b
Rated conditional short-circuit current:	3kA
Number of poles:	2, 4
Rated control supply voltage:	AC24V, 48V, 110V, 230V
Insulation class of coil:	E
Degree of protection:	IP20

**Tested according to:** EN 61095:2009

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 874102108002-00  
**Valid until:** 2026-07-06

**Date,** 2021-07-07

( Jie Zhu )