

IEC**IECEE**

®

™

Ref. Certif. No.

CN52997

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Circuit Breaker for Motor Protection

Name and address of the applicant

Saide Electric Co., Ltd.
Qiligang Town Industrial Zone, Yueqing, Zhejiang Province,
P.R.China

Name and address of the manufacturer

Saide Electric Co., Ltd.
Qiligang Town Industrial Zone, Yueqing, Zhejiang Province,
P.R.China

Name and address of the factory

Saide Electric Co., Ltd.
Qiligang Town Industrial Zone, Yueqing, Zhejiang Province,
P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

SAIDE

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SDM7-32, SDM7-32X;

Additional information (if necessary may also be reported on page 2)

IEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th Edition); IEC 60947-4-1:2018

A sample of the product was tested and found to be in conformity with

00901-CB2019CQC-088708-1, 00901-CB2019CQC-088708-2

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.10,2021

Signature:

Lu Mei


CB 0061529

SDM7-32, SDM7-32X;
Ui:690V;
Uimp:6kV;
Ue:AC400/415V;
In:0.1A~0.16A,0.16A~0.25A,0.25A~0.4A,0.4A~0.63A,0.63A~1A,1A~1.6A,
1.6A~2.5A,2.5A~4A,4A~6.3A,6A~10A,9A~14A,13A~18A,17A~23A,20A~25A,24A~32A;
Over current release type: Thermal magnetic;
Ics:100kA(0.1A~0.16A,0.16A~0.25A,0.25A~0.4A,0.4A~0.63A,0.63A~1A,1A~1.6A,1.6A~2.5A,2.5
A~4A,
4A~6.3A,6A~10A),7.5kA(9A~14A,13A~18A),6kA(17A~23A,20A~25A,24A~32A);
Icu:100kA(0.1A~0.16A,0.16A~0.25A,0.25A~0.4A,0.4A~0.63A,0.63A~1A,1A~1.6A,1.6A~2.5A,2.5
A~4A,
4A~6.3A,6A~10A),15kA(9A~14A,13A~18A,17A~23A,20A~25A),10kA(24A~32A);
Trip class:10A;
Selectivity category: A, AC-3;
3P;
Not suitable for insulation;
50/60Hz;
IP20;
Auxiliary contact:
AE11:1NO1NC、AE20:2NO;
Ith:2.5A;
AC-15:Ue/Ie:230V/0.5A;
AN11:1NO1NC、AN20:2NO;
Ith:6A;
AC-15:Ue/Ie:230V/3.3A;
AD1001:1NO1NC、AD1010:2NO、AD0101:2NC、AD0110:1NC1NO;
Ith:6A;
AC-15:Ue/Ie:220V/3.3A,240V/3.3A,
AC-14:Ue/Ie:220V/0.3A,240V/0.3A

Page 1 of 1

Additional information (if necessary)

Date: Mar.10,2021

Signature: 
Lu Mei